

ORDINANCE OF THE STATES OF DELIBERATION

ENTITLED

The Water Byelaws (Guernsey) Ordinance, 2003 *

[CONSOLIDATED TEXT]

NOTE

This consolidated version of the enactment incorporates all amendments listed in the footnote below. It has been prepared for the Guernsey Law website and is believed to be accurate and up to date, but it is not authoritative and has no legal effect. No warranty is given that the text is free of errors and omissions, and no liability is accepted for any loss arising from its use. The authoritative text of the enactment and of the amending instruments may be obtained from Her Majesty's Greffier, Royal Court House, Guernsey, GY1 2PB.

©States of Guernsey

* No. XI of 2003 (Recueil d'Ordonnances Tome XXIX, p. 306); as amended by the Machinery of Government (Transfer of Functions) (Guernsey) Ordinance, 2003 (No. XXXIII of 2003, Recueil d'Ordonnances Tome XXIX, p. 406); the Organisation of States' Affairs (Transfer of Functions) Ordinance, 2016 (No. IX of 2016).

**ORDINANCE
OF THE STATES OF DELIBERATION**

ENTITLED

The Water Byelaws (Guernsey) Ordinance, 2003

ARRANGEMENT OF SECTIONS

1. New Byelaws.
2. Repeals.
3. Citation and commencement.

SCHEDULE Byelaws Made By The States' Trading Supervisory Board.
Part I Preliminary.
Part II Requirements.
Part III Enforcement, Etc.

(Made on 28th May, 2003.)

The Water Byelaws (Guernsey) Ordinance, 2003

WHEREAS the States Water Board, on the 23rd day of January, 2003, in pursuance of Article 30 of the Law entitled "Loi ayant rapport à la Fourniture d'Eau par les États de cette Île aux Habitants de la dite Île" registered on the 7th day of May, 1927^a, made the Byelaws set out in the Schedule to this Ordinance:

THE STATES, in pursuance of their Resolution of the 1st day of November 2002^b, and in exercise of the powers vested in them by the said Article 30, hereby order: –

New Byelaws.

1. The Byelaws made by the [States' Trading Supervisory Board] on the 23rd day of January, 2003 and set out in the Schedule to this Ordinance are hereby sanctioned.

NOTES

In section 1, the words in square brackets were substituted by the Organisation of States' Affairs (Transfer of Functions) Ordinance, 2016, section 2, Schedule 1, paragraph 12(b), Schedule 2, Part 8, with effect from 1st May, 2016.¹

The functions, rights and liabilities of the Public Services Department and of its Minister or Deputy Minister arising under or by virtue of this Ordinance were transferred to and vested in, respectively, the States' Trading Supervisory Board and its President or Vice-President by the Organisation of States' Affairs (Transfer of Functions) Ordinance, 2016, section 1, Schedule 1, paragraph 12(b), Schedule 2, Part 8, with effect from 1st May, 2016, subject to the savings and transitional provisions in section 3 of the 2016 Ordinance.²

Repeals.

2. The Waterworks Byelaws Ordinance, 1948^c, the Waterworks

^a Ordres en Conseil Vol. VIII, p. 112.

^b Article XIX of Billet d'État No. XXII of 2002.

^c Recueil d'Ordonnances Tome VIII, p. 66.

Byelaws (Amendment) Ordinance, 1954^d, the Waterworks Byelaws (Amendment) Ordinance, 1956^e and the Waterworks Byelaws (Amendment) Ordinance, 1976^f are hereby repealed.

Citation and commencement.

3. This Ordinance may be cited as the Water Byelaws (Guernsey) Ordinance, 2003 and shall come into force on the 1st June, 2003.

d Recueil d'Ordonnances Tome XI, p. 40.
e Recueil d'Ordonnances Tome XI, p. 235.
f Recueil d'Ordonnances Tome XX, p. 415.

SCHEDULE Section 1
BYELAWS MADE BY THE [STATES' TRADING SUPERVISORY BOARD]

PART I
PRELIMINARY

Interpretation.

1. In these Byelaws –

"approved contractor" means a person who –

- (a) has been approved by the [States' Trading Supervisory Board] for the area where a water fitting is installed or used, or
- (b) has been certified in writing as an approved contractor by the [States' Trading Supervisory Board].

"fluid category" means a category of fluid described in Schedule 1 to these Byelaws,

"material change of use" means a change in the purpose for which, or the circumstances in which, premises are used, such that after that change the premises are used (where previously they were not so used) –

- (a) as a dwelling,
- (b) as an institution,
- (c) as a public building, or
- (d) for the purposes of the storage or use of substances which if mixed with water result in a fluid which is classified as either fluid category 4 or 5,

"supply pipe" means so much of any service pipe as is not vested in

the [States' Trading Supervisory Board],

"[States' Trading Supervisory Board]" means the States of Guernsey [States' Trading Supervisory Board],

and paragraph 1 of Schedule 2 to these Byelaws has effect for the purposes of these Byelaws.

Application of Byelaws.

2. (1) Subject to the following provisions of this Byelaw, these Byelaws apply to any water fitting installed or used, or to be installed or used, in premises to which water is or is to be supplied by the [States' Trading Supervisory Board].

(2) These Byelaws do not apply to a water fitting installed or used, or to be installed or used, in connection with water supplied for purposes other than domestic or food production purposes, provided that –

- (a) the water is metered,
- (b) the supply of the water is for a period not exceeding one month, or, with the written consent of the [States' Trading Supervisory Board], three months, and
- (c) no water can return through the meter to any pipe vested in the [States' Trading Supervisory Board].

(3) Except for the purposes of paragraph 13 of Schedule 2 to these Byelaws (prevention of cross connection to unwholesome water), these Byelaws do not apply to water fittings which are not connected or to be connected to water supplied by the [States' Trading Supervisory Board].

Provided that nothing in these Byelaws shall require any person to remove, replace, alter, disconnect or cease to use any water fitting which was lawfully installed or used, or capable of being used, before 1st January 2003.

PART II
REQUIREMENTS

Restriction on installation etc. of water fittings.

3. (1) No person shall –
- (a) install a water fitting to convey or receive water supplied by the [States' Trading Supervisory Board], or alter, disconnect or use such a water fitting, or
 - (b) cause or permit such a water fitting to be installed, altered, disconnected or used,

in contravention of the following provisions of this Part.

(2) No water fitting shall be installed, connected, arranged or used in such a manner that it causes or is likely to cause –

- (a) waste, misuse, undue consumption or contamination of water supplied by the [States' Trading Supervisory Board], or
- (b) the erroneous measurement of water supplied by the [States' Trading Supervisory Board].

(3) No water fitting shall be installed, connected, arranged or used which by reason of being damaged, worn or otherwise faulty, causes or is likely to cause –

- (a) waste, misuse, undue consumption or contamination of water supplied by the [States' Trading Supervisory Board], or
- (b) the erroneous measurement of water supplied by the [States' Trading Supervisory Board].

Requirements for water fittings etc.

4. (1) Every water fitting shall –
- (a) be of an appropriate quality and standard, and
 - (b) be suitable for the circumstances in which it is used.
- (2) For the purposes of this Byelaw, a water fitting is of an appropriate quality and standard only if –
- (a) it bears an appropriate CE marking,
 - (b) it conforms to an appropriate harmonized standard or European technical approval,
 - (c) it conforms to an appropriate British Standard or some other national specification which provides an equivalent level of protection and performance, or
 - (d) it conforms to a specification approved by the [States' Trading Supervisory Board].
- (3) Every water fitting shall comply with the requirements of Schedule 2 to these Byelaws as it applies to that fitting.
- (4) Where any requirement of Schedule 2 to these Byelaws relates to a water system, every water fitting which forms part of that system shall be fitted or, as the case may be, altered or replaced so as to comply with that requirement.
- (5) Every water fitting shall be installed, connected, altered, repaired or disconnected in a workmanlike manner.
- (6) For the purposes of this Byelaw, a water fitting is installed, connected, altered, repaired or disconnected in a workmanlike manner only if the work is carried out so as to conform –

- (a) to an appropriate British Standard, a European technical approval or some other national specification which provides an equivalent level of protection and performance,
- (b) to a specification approved by the [States' Trading Supervisory Board], or
- (c) to a method of installation approved by the [States' Trading Supervisory Board].

Notification.

5. (1) Subject to paragraph (2), any person who proposes to install a water fitting in connection with any of the operations listed in Schedule 3 to these Byelaws –

- (a) shall give notice to the [States' Trading Supervisory Board] that he proposes to begin work,
- (b) shall not begin that work without the consent of the [States' Trading Supervisory Board] which shall not be withheld unreasonably, and
- (c) shall comply with any conditions to which the [States' Trading Supervisory Board]'s consent is subject.

(2) The [States' Trading Supervisory Board] may withhold consent required under paragraph (1), or grant it subject to conditions, by a notice given before the expiry of the period of ten working days commencing with the day on which notice under that paragraph was given.

(3) If no notice is given by the [States' Trading Supervisory Board] within the period mentioned in paragraph (2), the consent required under paragraph (1) shall be deemed to have been granted unconditionally.

(4) This byelaw does not apply to the installation by an approved

contractor of a water fitting falling within paragraph 3 and 4 in the Schedule 3 to these Byelaws.

(5) The notice required by paragraph (1) shall include or be accompanied by –

- (a) the name and address of the person giving the notice, and (if different) the name and address of the person on whom notice may be served under paragraph (2),
- (b) a description of the proposed work or material change of use,
- (c) particulars of the location of the premises to which the proposal relates, and the use or intended use of those premises,
- (d) except in the case of a fitting falling within paragraph 4(a), (c) or (e) of Schedule 3 to these Byelaws –
 - (i) a plan of those parts of the premises to which the proposal relates, or
 - (ii) a diagram showing the pipework and fitting to be installed, and
- (e) where the work is to be carried out by an approved contractor, the name of the contractor.

Contractor's certificate.

6. (1) Where a water fitting is installed, altered, connected or disconnected, the contractor or installer shall upon completion of the work furnish a signed certificate stating whether the water fitting complies with the requirements of these Byelaws to the person who commissioned the work.

(2) In the case of a fitting for which notice is required under

Byelaw 5(1), the contractor shall send a copy of the certificate to the [States' Trading Supervisory Board].

PART III
ENFORCEMENT, ETC.

Contravention of Byelaws and defences.

7. (1) Subject to the following provisions of this Byelaw, a person who –

- (a) contravenes any of the provisions of Byelaws 3(1), (2) or (3) or 6(1) or (2),
- (b) commences an operation listed in Schedule 3 to these Byelaws without giving the notice required by Byelaw 5(1),
- (c) commences an operation listed in Schedule 3 to these Byelaws without the consent required by Byelaw 5(1), or
- (d) carries out an operation listed in Schedule 3 to these Byelaws in breach of a condition imposed under Byelaw 5(2),

is guilty of an offence and liable on summary conviction to a fine not exceeding level 3 on the uniform scale.

(2) In any proceedings against an owner or occupier for an offence under paragraph (1) which is based on the installation, alteration, repair, connection or disconnection of a water fitting, it shall be a defence to prove –

- (a) that the work in question was carried out by or under the direction of an approved contractor, and
- (b) that the contractor certified to the person who

commissioned that work that the water fitting complied with the requirements of these Byelaws.

Inspections, measurements and tests.

8. Any person designated in writing by the [States' Trading Supervisory Board] for the purposes of performing their duties under Section 30 of the 1927 law may carry out such inspections, measurements and tests on premises entered by that person or on water fittings or other articles found on any such premises, and take away such samples of water or of any land, and such water fittings and other articles, as that person may consider necessary for the purposes for which those premises were entered.

Enforcement.

9. The [States' Trading Supervisory Board] shall enforce the requirements of these Byelaws.

Relaxation of requirements.

10. (1) Where the [States' Trading Supervisory Board] considers that any requirement of Schedule 2 to these Byelaws would be inappropriate in relation to a particular case, the [States' Trading Supervisory Board] may relax that requirement by issuing written consent.

(2) The [States' Trading Supervisory Board] shall give notice of any proposed relaxation.

Approval by the [States' Trading Supervisory Board].

11. (1) Before approving a specification under Byelaw 4 or under Schedule 2 to these Byelaws, the [States' Trading Supervisory Board] shall consult –

- (a) such trade associations as it considers appropriate, and
- (b) such organisations appearing to it to be concerned with the interests of water users as it considers appropriate.

(2) Where the [States' Trading Supervisory Board] approves a specification under Byelaw 4 or under Schedule 2 to these Byelaws, the [States'

Trading Supervisory Board] shall give notice of the approval to all persons who were consulted under paragraph (1) and shall publish it as it considers appropriate.

(3) Where the [States' Trading Supervisory Board] approves a method of installation under Byelaw 4, the [States' Trading Supervisory Board] shall publish it in such manner as it considers appropriate.

(4) This Byelaw applies to the revocation or modification of an approval as it applies to the giving of that approval.

Disputes.

12. Any dispute between the [States' Trading Supervisory Board] and a person who has installed or proposes to install a water fitting –

- (a) as to whether the [States' Trading Supervisory Board] has unreasonably withheld consent, or attached unreasonable conditions, or
- (b) as to whether the [States' Trading Supervisory Board] has unreasonably refused to apply a relaxation of the requirements of these Byelaws,

shall be referred to arbitration by a single arbitrator to be appointed by agreement between the parties.

Revocation of byelaws.

13. The Byelaws made by the States Water Board in 1948^g for the Prevention of Waste, Undue Consumption, Misuse or Contamination of Water, and the Byelaws made by the States Water Board in 1954^h, 1956ⁱ and 1976^j which amend the said Byelaws of 1948, are repealed.

^g Recueil d'Ordonnances Tome VIII, p. 66.
^h Recueil d'Ordonnances Tome XI, p. 40.
ⁱ Recueil d'Ordonnances Tome XI, p. 235.
^j Recueil d'Ordonnances Tome XX, p. 415.

SCHEDULE 1
FLUID CATEGORIES

Byelaw 1

Fluid category 1.

Wholesome water supplied by the [States' Trading Supervisory Board].

Fluid category 2.

Water in fluid category 1 whose aesthetic quality is impaired owing to –

- (a) a change in its temperature, or
- (b) the presence of substances or organisms causing a change in its taste, odour or appearance,

including water in a hot water distribution system.

Fluid category 3.

Fluid which represents a slight health hazard because of the concentration of substances of low toxicity, including any fluid which contains –

- (a) ethylene glycol, copper sulphate solution or similar chemical additives, or
- (b) sodium hypochlorite (chloros and common disinfectants).

Fluid category 4.

Fluid which represents a significant health hazard because of the concentration of toxic substances, including any fluid which contains –

- (a) chemical, carcinogenic substances or pesticides (including insecticides and herbicides), or
- (b) environmental organisms of potential health significance.

Fluid category 5.

Fluid representing a serious health hazard because of the concentration of pathogenic organisms, radioactive or very toxic substances, including any fluid which contains –

- (a) faecal material or other human waste,
- (b) butchery or other animal waste, or
- (c) pathogens from any other source.

SCHEDULE 2
REQUIREMENTS FOR WATER FITTINGS

Byelaw 4(3)

Interpretation

1. In this Schedule –

"**backflow**" means flow upstream, that is in a direction contrary to the intended normal direction of flow, within or from a water fitting,

"**cistern**" means a fixed container for holding water at atmospheric pressure,

"**combined feed and expansion cistern**" means a cistern for supplying cold water to a hot water system without a separate expansion cistern,

"**combined temperature and pressure relief valve**" means a valve capable of performing the function of both a temperature relief valve and a pressure relief valve,

"**contamination**" includes any reduction in chemical or biological quality of water due to a change in temperature or the introduction of polluting substances,

"**distributing pipe**" means any pipe (other than a warning, overflow or flushing pipe) conveying water from a storage cistern, or from hot water apparatus supplied from a cistern and under pressure from that cistern,

"**expansion cistern**" or "**expansion vessel**" means a cistern or vessel connected to a water heating system which accommodates the increase in volume of water in the system when the water is heated from cold,

"**expansion valve**" means a pressure-activated valve designed to release expansion water from an unvented water heating system,

"flushing cistern" means a cistern provided with valve or device for controlling the discharge of the stored water into a water closet pan or urinal,

"overflow pipe" means a pipe from a cistern in which water flows only when the water level in the cistern exceeds a predetermined level,

"pressure relief valve" means a pressure-activated valve which opens automatically at a specified pressure to discharge fluid,

"primary circuit" means an assembly of water fittings in which water circulates between a boiler or other source of heat and a primary heat exchange inside a hot water storage vessel, and includes any space heating system,

"secondary circuit" means an assembly of water fittings in which water circulates in supply pipes or distributing pipes of a hot water storage system,

"secondary system" means an assembly of water fittings comprising the cold feed pipe, any hot water storage vessel, water heater and pipework from which hot water is conveyed to all points of draw-off,

"servicing valve" means a valve for shutting off for the purpose of maintenance or service the flow of water in a pipe connected to a water fitting,

"stopvalve" means a valve, other than a servicing valve, used for shutting off the flow of water in a pipe,

"storage cistern" means a cistern for storing water for subsequent use, not being a flushing cistern,

"temperature relief valve" means a valve which opens automatically at a specified temperature to discharge fluid,

"terminal fitting" means a water outlet device, and

"vent pipe" means a pipe open to the atmosphere which exposes the system to atmospheric pressure at its boundary.

Materials and substances in contact with water

2. (1) Subject to subparagraph (2), no material or substance, either alone or in combination with any other material or substance or with the contents of any water fitting of which it forms a part, which causes or is likely to cause contamination of water shall be used in the construction, installation, renewal, repair or replacement of any water fitting which conveys or receives, or may convey or receive, water supplied for domestic or food production purposes.

(2) This requirement does not apply to a water fitting downstream of a terminal fitting supplying wholesome water where –

- (a) the use to which the water downstream is put does not require wholesome water, and
- (b) a suitable arrangement or device to prevent backflow is installed.

Requirements for water fittings

3. Every water fitting shall –

- (a) be immune to or protected from corrosion by galvanic action or by any other process which is likely to result in contamination or waste of water, and
- (b) be constructed of materials of such strength and thickness as to resist damage from any external load, vibration, stress or settlement, pressure surges, or temperature fluctuation to which it is likely to be subjected.

4. Every water fitting shall –

- (a) be watertight,
- (b) be so constructed and installed as to
 - (i) prevent ingress by contaminants, and
 - (ii) inhibit damage by freezing or any other cause,
- (c) be so installed as to minimise the risk of permeation by, or deterioration from contact with, any substance which may cause contamination, and
- (d) be adequately supported.

5. No water fitting shall be installed, connected or used which is likely to have a detrimental effect on the quality or pressure of water in a water main or other pipe of the [States' Trading Supervisory Board].

6. (1) No water fitting which is designed to be operated or maintained, whether manually or electronically, or which consists of a mechanical joint shall be –

- (a) embedded in any wall or solid floor,
- (b) be installed below ground,
- (c) passed through or under any wall, footing or foundation.

(2) Any such fitting or mechanical backflow prevention device, not being a terminal fitting, shall be –

- (a) corrosion resistant to any material in direct contact,

- (b) installed to allow adequate thermal expansion and contraction,
- (c) embedded such that any leakage would become readily evident.

Water system design and installation

7. No water fitting shall be installed in such a position, or pass through such surroundings, that it is likely to cause contamination or damage to the material of the fitting or the contamination of water supplied by the [States' Trading Supervisory Board].

8. Any pipe supplying cold water for domestic purposes to any tap shall be so installed that, so far as is reasonably practicable, the water is not warmed above 25°C.

9. (1) Every supply pipe or distributing pipe providing water to separate premises shall be fitted with a stopvalve conveniently located to enable the supply to those premises to be shut off without shutting off the supply to any other premises.

(2) Where a supply pipe or distributing pipe provides water in common to two or more premises, it shall be fitted with a stopvalve to which each occupier of those premises has access.

10. Water supply systems shall be capable of being drained down and be fitted with an adequate number of servicing valves and drain taps so as to minimize the discharge of water when water fittings are maintained or replaced. A sufficient number of stopvalves shall be installed for isolating parts of the pipework.

11. (1) The water system shall be capable of withstanding an internal water pressure not less than 1½ times the maximum pressure to which the installation or relevant part is designed to be subjected in operation (**'the test pressure'**).

Consolidated text

- (2) This requirement shall be deemed to be satisfied –
 - (a) in the case of a water system that does not include a pipe, where –
 - (i) the whole system is subjected to the test pressure by pumping, after which the test continues for one hour without further pumping,
 - (ii) there is no loss of pressure or visible leakage at the end of the test.

12. Every water system shall be tested, flushed and where necessary disinfected before it is first used.

Prevention of cross connection to unwholesome water

- 13.** (1) Any water fitting conveying –
- (a) rain water, recycled water or any fluid other than water supplied by the [States' Trading Supervisory Board], or
 - (b) any fluid that is not wholesome water,

shall be clearly identified so as to be easily distinguished from any supply pipe or distributing pipe.

(2) No supply pipe, distributing pipe or pump delivery pipe drawing water from a supply pipe or distributing pipe shall convey, or be connected so that it can convey, any fluid falling within subparagraph (1) unless a device for preventing backflow is installed in accordance with paragraph 14.

Backflow prevention

Consolidated text

14. (1) Subject to the following provisions of this paragraph, every water system shall contain an adequate device or devices for preventing backflow of fluid from any appliance, fitting or process from occurring.

(2) Paragraph (1) does not apply to –

- (a) a water heater where the expanded water is permitted to flow back into a supply pipe, or
- (b) a vented water storage vessel supplied from a storage cistern,

where the temperature of the water in the supply pipe or the cistern does not exceed 25°C.

(3) The device used to prevent backflow shall be appropriate to the highest applicable fluid category to which the fitting is subject downstream before the next such device.

(4) Backflow prevention shall be provided on any supply pipe or distributing pipe –

- (a) where it is necessary to prevent backflow between separately occupied premises, or
- (b) where the [States' Trading Supervisory Board] has given notice for the purposes of this Schedule that such prevention is needed for the whole or part of any premises.

(5) A backflow prevention device is adequate for the purposes of paragraph (1) if it is in accordance with a specification approved by the [States' Trading Supervisory Board] for the purposes of this Schedule.

Cold water services

Consolidated text

15. (1) Every pipe supplying water connected to a storage cistern shall be fitted with an effective adjustable valve capable of shutting off the inflow of water at a suitable level below the overflowing level of the cistern.

(2) Every inlet to a storage cistern, combined feed and expansion cistern, WC flushing cistern or urinal flushing cistern shall be fitted with a servicing valve on the inlet pipe adjacent to the cistern.

(3) Every storage cistern, except one supplying water to the primary circuit of a heating system, shall be fitted with a servicing valve on the outlet pipe.

(4) Every storage cistern shall be fitted with –

(a) an overflow pipe, with a suitable means of warning of an impending overflow, which excludes insects,

(b) a cover positioned so as to exclude light and insects, and

(c) thermal insulation to minimize freezing or undue warming.

(5) Every storage cistern shall be so installed as to minimise the risk of contamination of stored water. The cistern shall be of an appropriate size, and the pipe connections to the cistern shall be so positioned, as to allow free circulation and to prevent areas of stagnant water from developing.

Hot water services

16. (1) Every unvented water heater, not being an instantaneous water heater with a capacity not greater than 15 litres, and every secondary coil contained in a primary system shall –

(a) be fitted with a temperature control device, and either

a temperature relief valve or a combined temperature and pressure relief valve,

- (b) be capable of accommodating expansion within the secondary hot water system.

(2) An expansion valve shall be fitted with provision to ensure that water is discharged in a correct manner in the event of a malfunction of the expansion vessel or system.

17. Appropriate vent pipes, temperature control devices and combined temperature pressure and relief valves shall be provided to prevent the temperature of the water within a secondary hot water system from exceeding 100°C.

18. Discharges from temperature relief valves, combined temperature pressure and relief valves and expansion valves shall be made in a safe and conspicuous manner.

19. (1) No vent pipe from a primary circuit shall terminate over a storage cistern containing wholesome water for domestic supply or for supplying water to a secondary system.

(2) No vent pipe from a secondary circuit shall terminate over any combined feed and expansion cistern connected to a primary circuit.

20. Every expansion cistern or expansion vessel, and every cold water combined feed and expansion cistern connected to a primary circuit, shall be such as to accommodate any expansion water from that circuit during normal operation.

21. (1) Every expansion valve, temperature relief valve or combined temperature and pressure relief valve connected to any fitting or appliance shall close automatically after, a discharge of water.

(2) Every expansion valve shall –

- (a) be fitted on the supply pipe close to the hot water

vessel and without any intervening valves, and

- (b) only discharge water when subjected to a water pressure of not less than 0.5 bar (50 kPa) above the pressure to which the hot water vessel is, or is likely to be, subjected in normal operation.

22. (1) A temperature relief valve or combined temperature and pressure relief valve shall be provided on every unvented hot water storage vessel with a capacity greater than 15 litres.

(2) The valve shall –

- (a) be located directly on the vessel in an appropriate location, and have a sufficient discharge capacity, to ensure that the temperature of the stored water does not exceed 100°C; and
- (b) only discharge water at below its operating temperature when subjected to a pressure of not less than 0.5 bar (50 kPa) in excess of the greater of the following –
 - (i) the maximum working pressure in the vessel in which it is fitted, or
 - (ii) the operating pressure of the expansion valve.

(3) In this paragraph "**unvented hot water storage vessel**" means a hot water storage vessel that does not have a vent pipe to the atmosphere.

23. No supply pipe or secondary circuit shall be permanently connected to a closed circuit for filling a heating system unless it incorporates a backflow prevention device in accordance with a specification approved by the [States' Trading Supervisory Board] for the purposes of this Schedule.

WC's, flushing devices and urinals

24. (1) Subject to the following provisions of this paragraph –
- (a) every water closet pan shall be supplied with water from a flushing cistern, pressure flushing cistern or pressure flushing valve, and shall be so made and installed that after normal use its contents can be cleared effectively by a single flush of water, or, where the installation is designed to receive flushes of different volumes, by the largest of those flushes,
 - (b) no pressure flushing valve shall be installed in any building where a minimum flow rate of 1.2 litres per second cannot be achieved at the appliance,
 - (c) no flushing device installed for use with a WC pan shall give a single flush exceeding 6 litres,
 - (d) no flushing device designed to give flushes of different volumes shall have a lesser flush exceeding two-thirds of the largest flush volume,
 - (e) every flushing cistern; other than a pressure flushing cistern, shall be clearly marked internally with an indelible line to show the intended volume of flush, together with an indication of that volume,
 - (f) a flushing device designed to give flushes of different volumes –
 - (i) shall have a readily discernible method of actuating the flush at different volumes, and
 - (ii) shall have instructions, clearly and permanently marked on the cistern or displayed nearby, for

Consolidated text

operating it to obtain the different volumes of flush,

- (g) every flushing cistern, not being a pressure flushing cistern or a urinal cistern, shall be fitted with a warning pipe or with a no less effective device,
- (h) every urinal that is cleared by water after use shall be supplied with water from a flushing device which –
 - (i) in the case of a flushing cistern, is filled at a rate suitable for the installation,
 - (ii) in all cases, is designed or adapted to supply no more water than is necessary for effective flow over the internal surface of the urinal and for replacement of the fluid in the trap, and
- (i) except in the case of a urinal which is flushed manually, or which is flushed automatically by electronic means after use, every pipe which supplies water to a flushing cistern or trough used for flushing a urinal shall be fitted with an isolating valve controlled by a time switch and a lockable isolating valve, or with some other equally effective automatic device for regulating the periods during which the cistern may fill.

(2) Every water closet, and every flushing device designed for use with a water closet, shall comply with a specification approved by the [States' Trading Supervisory Board] for the purposes of this Schedule.

(3) The requirements of subparagraphs (1) and (2) do not apply where faeces or urine are disposed of through an appliance that does not solely use fluid to remove the contents.

(4) The requirement in subparagraph (1)(h) shall be deemed to be satisfied –

(a) in the case of an automatically operated flushing cistern servicing urinals which is filled with water at a rate not exceeding –

(i) 10 litres per hour for a cistern serving a single urinal,

(ii) 7.5 litres per hour per urinal bowl or stall, or, as the case may be, for each 700mm width of urinal slab, for a cistern serving two or more urinals,

(b) in the case of a manually or automatically operated pressure flushing valve used for flushing urinals which delivers not more than 1.5 litres per bowl or position each time the device is operated.

(5) Notwithstanding subparagraph (1)(c), a flushing cistern installed before 1st January 2003 may be replaced by a cistern which delivers a similar volume and which may be either single flush or dual flush; but a single flush cistern may not be so replaced by a dual flush cistern.

(6) In this paragraph –

'pressure flushing cistern' means a WC flushing device that utilises the pressure of water within the cistern supply pipe to compress air and increase the pressure of water available for flushing a WC pan,

'pressure flushing valve' means a self-closing valve supplied with water directly from a supply pipe or a distributing pipe which when activated will discharge a pre-determined flush volume,

'trap' means a pipe fitting, or part of a sanitary appliance, that

retains liquid to prevent the passage of foul air, and

"warning pipe" means an overflow pipe whose outlet is located in a position where the discharge of water can readily be seen.

Baths, sinks, showers and taps

25. All premises supplied with water for domestic purposes shall have at least one tap conveniently situated for the drawing of drinking water.

26. A drinking water tap shall be supplied with water from –

- (a) a supply pipe,
- (b) a pump delivery pipe drawing water from a supply pipe, or
- (c) a distributing pipe drawing water exclusively from a storage cistern supplying wholesome water.

27. (1) Subject to subparagraph (2), every bath, wash basin, sink or similar appliance shall be provided with a watertight and readily accessible plug or other device capable of closing the waste outlet.

(2) This requirement does not apply to –

- (a) an appliance where the only taps provided are spray taps,
- (b) a washing trough or wash basin whose waste outlet is incapable of accepting a plug and to which water is delivered at a rate not exceeding 0.06 litres per second exclusively from a fitting designed or adapted for that purpose,
- (c) a wash basin or washing trough fitted with self-closing

taps,

- (d) a shower bath or shower tray,
- (e) a drinking water fountain or similar facility, or
- (f) an appliance which is used in medical, dental or veterinary premises and is designed or adapted for use with an unplugged outlet.

Washing machines, dishwashers and other appliances

28. (1) Subject to subparagraph (2), clothes washing machines, clothes washer-driers and dishwashers shall be economical in the use of water.

(2) The requirements of this paragraph shall be deemed to be satisfied in the case of machines having a water consumption per cycle of not greater than the following –

- (a) for domestic horizontal axis washing machines, 27 litres per kilogram of washload for a standard 60°C cotton cycle,
- (b) for domestic washer-driers, 48 litres per kilogram of washload for a standard 60°C cotton cycle,
- (c) for domestic dishwashers, 4.5 litres per place setting.

Water for outside use

29. Every pipe which conveys water to a drinking vessel for animals or poultry shall be fitted with –

- (a) a float-operated valve, or some other no less effective device to control the inflow of water, which is –

Consolidated text

- (i) protected from damage and contamination, and
 - (ii) prevents contamination of the water supply,
and
- (b) a stopvalve or servicing valve as appropriate.

30. Every pond, fountain, or pool shall have an impervious lining or membrane to prevent the leakage or seepage of water.

SCHEDULE 3

Byelaw 5

1. The erection of a building or other structure, including a pond or swimming pool with a capacity greater than 10,000 litres.
2. A material change of use of any premises.
3. The extension or alteration of a water system on any premises other than a house.
4. The installation of –
 - (a) a bidet with an ascending spray of flexible hose,
 - (b) a pump or booster drawing more than 12 litres per minute, connected directly to a supply pipe,
 - (c) a water treatment unit which produces a waste water discharge or which requires the use of water for regeneration or cleaning,
 - (d) a reduced pressure zone valve assembly or other mechanical device for protection against a fluid which is in fluid category 4 or 5,
 - (e) a garden watering system unless designed to be operated by hand, or
 - (f) any water system laid outside a building and either less than 750mm or more than 1350mm below ground level.

NOTES

In the Schedule, the words "States' Trading Supervisory Board" in square brackets, wherever occurring, were substituted by the Organisation of States' Affairs (Transfer of Functions) Ordinance, 2016, section 2, Schedule

1, paragraph 12(b), Schedule 2, Part 8, with effect from 1st May, 2016.³

*The functions, rights and liabilities of the Public Services Department and of its Minister or Deputy Minister arising under or by virtue of this Ordinance were transferred to and vested in, respectively, the States' Trading Supervisory Board and its President or Vice-President by the Organisation of States' Affairs (Transfer of Functions) Ordinance, 2016, section 1, Schedule 1, paragraph 12(b), Schedule 2, Part 8, with effect from 1st May, 2016, subject to the savings and transitional provisions in section 3 of the 2016 Ordinance.*⁴

¹ These words were previously substituted by the Machinery of Government (Transfer of Functions) (Guernsey) Ordinance, 2003, section 2, Schedule 1, paragraph 31, with effect from 6th May, 2004.

² The functions, rights and liabilities of the Public Services Department and its Minister arising under or by virtue of this Ordinance were previously transferred to and vested in them, respectively, from the Water Board and its President by the Machinery of Government (Transfer of Functions) (Guernsey) Ordinance, 2003, section 1, Schedule 1, paragraph 31, with effect from 6th May, 2004, subject to the savings and transitional provisions in section 4 of the 2003 Ordinance.

³ These words were previously substituted by the Machinery of Government (Transfer of Functions) (Guernsey) Ordinance, 2003, section 2, Schedule 1, paragraph 31, with effect from 6th May, 2004.

⁴ The functions, rights and liabilities of the Public Services Department and its Minister arising under or by virtue of this Ordinance were previously transferred to and vested in them, respectively, from the Water Board and its President by the Machinery of Government (Transfer of Functions) (Guernsey) Ordinance, 2003, section 1, Schedule 1, paragraph 31, with effect from 6th May, 2004, subject to the savings and transitional provisions in section 4 of the 2003 Ordinance.