

GUERNSEY STATUTORY INSTRUMENT

1962 - No. 21

The Safety of Employees (Miscellaneous Provisions)
Ordinance, 1952

Certificate of Exemption No. 15

Steam Boilers - Steam Drying Units.

Made 2nd November, 1962.

Coming into Operation 2nd November, 1962.

THE STATES LABOUR AND WELFARE COMMITTEE, as the Administering Authority constituted by the States under the Health, Safety and Welfare of Employees Law, 1950, and in pursuance of section eighteen of the Safety of Employees (Miscellaneous Provisions) Ordinance, 1952, hereby except from the provisions of sub-section (6) of section fifteen of the said Ordinance any steam drying unit forming part of a steam boiler the maximum working pressure of which does not exceed fifty pounds per square inch, subject to the following conditions:-

- (1) the steam drying unit shall have attached to it a suitable and separate safety valve;
- (2) the external covering of the steam drying chamber shall be properly sealed to prevent any ingress of water;
- (3) the steam drying unit shall be thoroughly examined by a competent person and subjected to a hydraulic test at least once in every period of six years.

Dated this second day of November,
nineteen hundred and sixty-two

(Signed) D. E. GALLIENNE

President
of the States Labour and Welfare Committee
for and on behalf of the Committee.